



Phone: (573) 364-8659

FAX: (573) 364-8602

e-mail: mkreyling@rollacity.gov

DEPARTMENT OF PUBLIC WORKS

901 North Elm

P.O. Box 979

Rolla, MO 65402

www.rollacity.gov

**PROJECT 541
NEW ANIMAL SHELTER
PHASE 3 - FENCING
JULY 27, 2026**

ADDENDUM NO. 2

1. All post and frame material for exterior fencing and kennels shall be SS40 steel pipe.
2. Kennel framing and gates shall be 1-5/8-inch diameter. Exterior fencing shall have 2-inch diameter line posts, with corner posts one size larger.
3. All gates including kennels shall have drop fork latches. Latches shall be able to be locked with a padlock.
4. Exterior walk gates shall be 5 feet wide. The perimeter fence drive gate shall be 20 feet wide (2x 10ft gates). The dumpster enclosure gate shall provide a minimum of 14 feet of clearance between the gate posts (2x 7ft gates minimum).
5. Include a copy of all addenda and acknowledge all addenda on the itemized bid form when submitting your bid.
6. The Bid Date remains the same.

End of Addendum.

